



06 FEBRUARY 2020

Fossil Fuel Free at Last: Air-to-Water Heat Pump and Ventilation Retrofit Case Study

Brian Just



Learning objectives

- Learn how air-to-water heat pumps are functioning in New England's Climate Zone 6
- Identify 5 key non-energy benefits that can help move the needle on HVAC retrofit projects
- Understand the basics of how to install an air-to-water heat pump with the benefit of an open-source design and detailed photographs
- Learn the key design features and options for low-temperature distribution, including how to set up a new home for near-seamless retrofittability in the future at minimal cost

Outline

- Goals
- Heat pump basics
- Decisions 101
- Design
- Installation
- Results
- Closing thoughts

Goals










A large pile of crumpled and torn US dollar bills, including a prominent one-dollar bill in the foreground. The bills are scattered and overlapping, with some showing signs of wear and discoloration. The text "Not (necessarily) a top goal:" is overlaid in white on the top left.

Not (necessarily)
a top goal:


Heat pump basics



Types




Types




Operating temperatures

Typical boiler



AWHP



Heat pump basics



Intake

Heat pump basics



Intake



Exhaust

Advantages of hydronics

- Distribution efficiency
 - Furnace → $30,000 \text{ btuh} / 750\text{W} = 40 \text{ btuh/W}$
 - Boiler → $30,000 \text{ btuh} / 75\text{W} = 400 \text{ btuh/W}$
 - No duct losses (if they leak, you know it)
 - Given volume of water can hold 3500x more heat than air
 - ½" tube compared to large round / rectangular ducts

Advantages of hydronics

- Distribution efficiency
 - Furnace → $30,000 \text{ btuh} / 750\text{W} = 40 \text{ btuh/W}$
 - Boiler → $30,000 \text{ btuh} / 75\text{W} = 400 \text{ btuh/W}$
 - No duct losses (if they leak, you know it)
 - Given volume of water can hold 3500x more heat than air
 - ½" tube compared to large round / rectangular ducts
- No moving air
 - Quiet
 - With minisplits, can blow cold air during defrost cycle
 - Less movement of dust and allergens

Advantages of hydronics

- Distribution efficiency
 - Furnace → $30,000 \text{ btuh} / 750\text{W} = 40 \text{ btuh/W}$
 - Boiler → $30,000 \text{ btuh} / 75\text{W} = 400 \text{ btuh/W}$
 - No duct losses (if they leak, you know it)
 - Given volume of water can hold 3500x more heat than air
 - ½" tube compared to large round / rectangular ducts
- No moving air
 - Quiet
 - With minisplits, can blow cold air during defrost cycle
 - Less movement of dust and allergens
- Placement and comfort
 - Put where you want them (e.g. below windows)
 - Invisible if you want (floors, walls, ceilings)
 - Highly tune-able to individual rooms and spaces, even those with very low loads

AWHP installation pros and cons

Pros

- Contractor network skilled at hydronics
- Boilers in 60% of VT homes
- AWHPs common in developed world

AWHP installation pros and cons

Pros

- Contractor network skilled at hydronics
- Boilers in 60% of VT homes
- AWHPs common in developed world

Cons


- In most cases, not a drop-in replacement
- Distribution system must be (made) compatible
 - Need surface area!
 - Existing baseboard and radiators may only put out 25-30% of the heat (180F vs. 120F)

Decisions 101




Basics

- 2 stories
- Slab-on-grade (no basement)
- 2100 square feet
- No cooling
- No cooling
- Heating provided by 17-yr-old propane boiler
 - Level 2: Baseboard in 4 rooms
 - Level 1: Radiant slab
 - Indirect tank for hot water




Basics

- 2 stories
- Slab-on-grade (no basement)
- 2100 square feet
- No cooling
- No cooling
- Heating provided by 17-yr-old propane boiler
 - Level 2: Baseboard in 4 rooms
 - Level 1: Radiant slab
 - Indirect tank



Is there a problem?

- Upstairs is freezing or sweltering due to poor design




Is there a problem?

- Upstairs is freezing or sweltering due to poor design
- Boiler represents carbon monoxide hazard



Is there a problem?

- Upstairs is freezing or sweltering due to poor design
- Boiler represents carbon monoxide hazard
- Poor distribution of underfloor slab heat



Is there a problem?

- Upstairs is freezing or sweltering due to poor design
- Boiler represents carbon monoxide hazard
- Poor distribution of underfloor slab heat
- Mechanical room is sauna in summer due to water heat

Is there a problem?

- Upstairs is freezing or sweltering due to poor design
- Boiler represents carbon monoxide hazard
- Poor distribution of underfloor slab heat
- Mechanical room is sauna in summer due to water heat
- **And more!**

Why air-to-water?

Option 1: (Passive)

- Let this one die
- Emergency installation of replacement boiler

Emergency HVAC Service

**Bundle up,
then give us a call!**


Why air-to-water?

Option 1: (Passive)

- Let this one die
- Emergency installation of replacement boiler

Option 2: (Active)

- Install multiple 1/1 minisplits (not a multizone) throughout home
- Abandon hydronic infrastructure



Before:



After:



Photos: EFG

Why air-to-water?

Option 1: (Passive)

- Let this one die
- Emergency installation of replacement boiler

Option 2: (Active)

- Install multiple 1/1 minisplits (not a multizone) throughout home
- Abandon hydronic infrastructure

Option 3: (Active)

- AWHP or hybrid system
- Utilize and enhance hydronic infrastructure

Air-to-Water Heat Pumps
Qualifying Products (Sorted by Manufacturer)
Effective 1/1/2019



Manufacturer	Model #	Model/Series Name	System Type	Nominal Capacity	COP @ ASW110*	Product Incentive
Aermec	ANK030H	ANK	Mono-bloc	2.5	1.85	\$2,500
	ANK030HP			2.5	1.85	\$2,500
	ANK030HA			2.5	1.85	\$2,500
	ANK045H			3	1.95	\$3,000
	ANK045HP			3	1.95	\$3,000
	ANK045HA			3	1.95	\$3,000
	ANK050H			4	2.07	\$4,000
	ANK050HP			4	2.07	\$4,000
	ANK050HA			4	2.07	\$4,000
Arctic Heat Pumps	020A	EVI - Cold Climate	Mono-bloc	2.5	2.26	\$2,500
	040A			4	2.18	\$4,000
	060A			5	2.26	\$5,000
Chiltrix	CX34-ODU	CX34	Mono-bloc	3	2	\$3,000
Nordic	ATW-45-HACW	ATW Series	Split	3	1.8*	\$3,000
	ATW-55-HACW			4	1.8*	\$4,000
	ATW-65-HACW			5	1.8*	\$5,000
	ATW-75-HACW			6	1.8*	\$6,000
SpacePak	LAHP4BA4	Solstice Extreme	Mono-bloc	4	2.55	\$4,000

* Equivalent value. Equipment automatically reduces outlet water temperature to 105F when ambient conditions drop to 5F

Trajectory

In addition to goals around **(no) fossil fuels**, **health/safety**, and big-picture **efficiency**,

- Enhance comfort, including room-by-room “tuneability”
- Retain infrastructure (radiant slab)
- Align project with other work in home

Design



~~Problems~~

Opportunity breakdown




3 spaces to deal with

1. First floor / Zone 1
2. Second floor / Zone 2
3. Mechanical room

1. First floor opportunities

- Unbalanced heating loop lengths




#	Location	SF served	Details	Length, est.
1	Kitchen + dining	200	12" spacing	250'
2	Dining + living perimeter	120		320'
3	Living + lower landing	300	12" spacing	380'
4	Entry + hall to den	80	12" spacing	140'
5	Den + half-bath	160	12" and 8" mix	220'

1. First floor opportunities

- Unbalanced heating loop lengths
- No intentional fresh air delivered within home

2. Second floor opportunities

- Series heating loop, no room-by-room control



2. Second floor opportunities


- Series heating loop, no room-by-room control
- Requires 180F water

2. Second floor opportunities

- Series heating loop, no room-by-room control
- Requires 180F water
- Thermostat in nonsensical location

2. Second floor opportunities

- Series heating loop, no room-by-room control
- Requires 180F water
- Thermostat in nonsensical location
- No fresh air provided to bedrooms



3. Mechanical room opportunities

- Overheats all summer long due to waste heat from boiler heating indirect water tank
- Underutilized space because of temperature instability

1/3. Choose the AWHP



AWHP choices

Air-to-Water Heat Pumps
Qualifying Products (Sorted by Manufacturer)
Effective 12/1/2019

Manufacturer	Model#	Model/Configuration	Service Type	Minimum Capacity	SEER at 45°F/55°F	Product Source
Aermec	AWHP0100			1.0	1.85	\$9,500
	AWHP0120			1.2	1.85	\$9,500
	AWHP0140			1.4	1.85	\$9,500
	AWHP0160			1.6	1.85	\$9,500
	AWHP0180			1.8	1.85	\$9,500
	AWHP0200			2.0	1.85	\$9,500
	AWHP0220			2.2	1.85	\$9,500
	AWHP0240			2.4	1.85	\$9,500
	AWHP0260			2.6	1.85	\$9,500
	AWHP0280			2.8	1.85	\$9,500
Arctic	AWHP0100	AWHP	Monobloc	1.0	1.85	\$9,500
	AWHP0120	AWHP	Monobloc	1.2	1.85	\$9,500
Chiltrix	AWHP0100	AWHP	Monobloc	1.0	1.85	\$9,500
	AWHP0120	AWHP	Monobloc	1.2	1.85	\$9,500
Nordic	AWHP0100	AWHP	Monobloc	1.0	1.85	\$9,500
	AWHP0120	AWHP	Monobloc	1.2	1.85	\$9,500
SpacePak	AWHP0100	AWHP	Monobloc	1.0	1.85	\$9,500
	AWHP0120	AWHP	Monobloc	1.2	1.85	\$9,500

*Equivalent value. Equipment automatically reduces outdoor water temperature to 50°F when ambient conditions drop to 10°F.
For more information, visit <https://www.efficiencyvermont.com/energytraining.cfm>

Manufacturer	Configuration	Available?
Aermec	Mono-bloc	Yes
Arctic	Mono-bloc	Yes
Chiltrix	Mono-bloc	Yes
Nordic	Split (condenser <i>inside</i>)	Yes
SpacePak	Mono-bloc	Yes
SpacePak split	Split (condenser <i>inside</i>)	?
NIBE (Sweden) / Enertech	Split (condenser <i>outside</i>)	?
Dimplex (Germany) / Taco	Split (condenser <i>outside</i>)	?
Stiebel Eltron	Split (condenser <i>outside</i>)	?
Sanden Eco Runo*	Mono-bloc	?

* Uses CO₂ as refrigerant

AWHP selection

Air-to-Water Heat Pumps
Qualifying Products (Sorted by Manufacturer)
Effective 12/31/2019

Manufacturer	Model#	Brand/Configuration	Service Type	Minimum Capacity	SEER at 45°F/45°F	Product Source
Aermec	AWHP020P	AWHP	Mono-bloc	2.5	1.85	\$8,500
	AWHP030P			3.5	1.85	\$8,500
	AWHP040P			4.5	1.85	\$8,500
	AWHP050P			5.5	1.85	\$8,500
	AWHP060P			6.5	1.85	\$8,500
	AWHP070P			7.5	1.85	\$8,500
	AWHP080P			8.5	1.85	\$8,500
	AWHP090P			9.5	1.85	\$8,500
	AWHP100P			10.5	1.85	\$8,500
	AWHP110P			11.5	1.85	\$8,500
Arctic Heat Pumps	ARHP	AWHP - Cold Climate	Mono-bloc	2.5	2.25	\$8,500
	ARHP	AWHP	Mono-bloc	4	2.25	\$8,500
Chiltrix	CHHP	AWHP	Mono-bloc	2.5	2.25	\$8,500
	CHHP	AWHP	Mono-bloc	4	2.25	\$8,500
Nordic	NHP	AWHP	Split	2.5	2.84	\$8,500
	NHP	AWHP	Split	4	2.84	\$8,500
SpacePak	SPHP	AWHP	Mono-bloc	2.5	2.25	\$8,500
	SPHP	AWHP	Mono-bloc	4	2.25	\$8,500

*Equivalent values. Equipment automatically reduces outdoor water temperature by 10°F when ambient conditions drop to 1°F.
For more information, visit <https://www.efficiencyvermont.com/energy/heatpumps>

Manufacturer	Configuration	Available?
Aermec	Mono-bloc	Yes
Arctic	Mono-bloc	Yes
Chiltrix	Mono-bloc	Yes
Nordic	Split (condenser <i>inside</i>)	Yes
SpacePak	Mono-bloc	Yes
SpacePak split	Split (condenser <i>inside</i>)	?
NIBE (Sweden) / Enertech	Split (condenser <i>outside</i>)	?
Dimplex (Germany) / Taco	Split (condenser <i>outside</i>)	?
Stiebel Eltron	Split (condenser <i>outside</i>)	?
Sanden Eco Runo*	Mono-bloc	?

* Uses CO₂ as refrigerant

AWHP selection

Air-to-Water Heat Pumps
Qualifying Products (Sorted by Manufacturer)
Effective 12/1/2019

Manufacturer	Model#	Brand/Configuration	Service Type	Minimum Capacity	SEER at 45°F/55°F	Product Source
Aermec	AWHP0100	Mono-Bloc	Mono-Bloc	1.5	1.85	\$9,500
	AWHP0120			2.5	1.85	\$9,500
	AWHP0140			3.5	1.85	\$9,500
	AWHP0160			4.5	1.85	\$9,500
	AWHP0180			5.5	1.85	\$9,500
	AWHP0200			6.5	1.85	\$9,500
	AWHP0220			7.5	1.85	\$9,500
	AWHP0240			8.5	1.85	\$9,500
	AWHP0260			9.5	1.85	\$9,500
	AWHP0280			10.5	1.85	\$9,500
Arctic	ARCTIC	Mono-Bloc	Mono-Bloc	1.5	1.85	\$9,500
	ARCTIC			2.5	1.85	\$9,500
Chiltrix	CHILTRIX	Mono-Bloc	Mono-Bloc	1.5	1.85	\$9,500
	CHILTRIX			2.5	1.85	\$9,500
Nordic	NORDIC	Split (condenser inside)	Split (condenser inside)	1.5	1.85	\$9,500
	NORDIC			2.5	1.85	\$9,500
SpacePak	SPACEPAK	Mono-Bloc	Mono-Bloc	1.5	1.85	\$9,500
	SPACEPAK			2.5	1.85	\$9,500

*Equivalent values. Equipment automatically reduces outdoor water temperature by 10°F when ambient conditions drop to 34°F.
For more information, visit <https://www.energysave.com/energy-saving/awhp>

Manufacturer	Configuration	Available?
Aermec	Mono-bloc	Yes
Arctic	Mono-bloc	Yes
Chiltrix	Mono-bloc	Yes
Nordic	Split (condenser <i>inside</i>)	Yes
SpacePak	Mono-bloc	Yes
SpacePak split	Split (condenser <i>inside</i>)	2020?
NIBE (Sweden) / Enertech	Split (condenser <i>outside</i>)	2020?
Dimplex (Germany) / Taco	Split (condenser <i>outside</i>)	2020?
Stiebel Eltron	Split (condenser <i>outside</i>)	2020?
Sanden Eco Runo*	Mono-bloc	?

* Uses CO₂ as refrigerant

More on these later...

Sizing

Heating design load 32.3 kBtu/h (-6F / 68F)

At 5F → 28.1 kBtu/h

Performance Tables ATW-65-HACW-P-1T *R410a, 60 Hz, ZPS51K5E-PFV*

OUTDOOR			ELECTRICAL		INDOOR						
Outdoor Air Temperature	Evaporating Temperature	Heat Absorbed (Btu/hr)	Compressor Current (A)	Input Power (W)	ELT	Condensing Temperature	Liquid Flow (gpm)	LLT	Delta T	Heating (Btu/hr)	COP _H
-5°F	-16°F	7,600	20.7	4730	102°F	110°F			3°F	23,400	1.45
5°F	-8°F	13,600	19.3	4410	101°F	109°F			4°F	28,300	1.88
15°F	1°F	19,200	17.8	4100	100°F	109°F			5°F	32,900	2.35
25°F	9°F	24,800	17.1	3950	100°F	109°F			5°F	37,900	2.81

Performance Tables ATW-55-HACW-P-1T *R410a, 60 Hz, ZPS40K5E-PFV*

OUTDOOR			ELECTRICAL		INDOOR						
Outdoor Air Temperature	Evaporating Temperature	Heat Absorbed (Btu/hr)	Compressor Current (A)	Input Power (W)	ELT	Condensing Temperature	Liquid Flow (gpm)	LLT	Delta T	Heating (Btu/hr)	COP _H
-5°F	-16°F	6,810	16.7	3870	102°F	110°F			3°F	19,800	1.50
5°F	-8°F	11,800	15.7	3670	101°F	109°F			4°F	24,100	1.93
15°F	1°F	16,200	14.8	3470	100°F	109°F			5°F	27,800	2.35
25°F	9°F	21,400	14.0	3290	100°F	109°F			5°F	32,400	2.89

Options

Purchased add-ons:

- 15" leg kit (\$100)
- Isolation pad for indoor unit (\$83)
- Compressor sound jacket (\$53)

Plus:

- 70 gallon buffer tank with 9 kW backup
- 9 kW = 30.7 kBtu/h

2/3. Choose heat emitters



Distribution

- Slab works well with 120F water
- Existing baseboard upstairs does not
 - without redesign, **cannot** effectively heat with outside temperatures below 45F

Upstairs options

Low temperature / high output baseboard

- Looks like normal baseboard but works with lower water temperatures
- Examples:
 - Mestek Synergy
 - Smith HE2 Heating Ed
 - Smith HE3 Silent Fin



Upstairs options

Low temperature / high output baseboard

Panel radiators

- Common worldwide
- Many manufacturers
- Room-by-room control
- No power needed



Image: <https://www.bosch-thermotechnology.us/us/en/ocs/residential/buderus-panel-radiators-1098983-p/>

Upstairs options

Low temperature / high output baseboard

Panel radiators

Panel radiators + fan assist

- Higher output
- Needs 24V



Images:
https://runtalnorthamerica.com/pdfs/RuntaL_NEO_Brochure.pdf



Upstairs options

Low temperature / high output baseboard

Panel radiators

Panel radiators + fan assist

Site-built radiant floors, walls, or ceilings



Photo credits: John Siegenthaler

Upstairs options

Low temperature / high output baseboard

Panel radiators

Panel radiators + fan assist

Site-built radiant floors, walls, or ceilings

Fan coil units



Image:
<http://spacepak.com/ThinWall.html>

Upstairs options

Low temperature / high output baseboard

Panel radiators

Panel radiators + fan assist

Site-built radiant floors, walls, or ceilings

Fan coil units

~~Existing baseboard and copper piping~~

**3/3. Come up with a design
that pulls it all together**



Scope creep

1. Need to run new distribution upstairs

Scope creep

1. Need to run new distribution upstairs
2. ... which helps justify putting in a ventilation system at the same time

Scope creep

1. Need to run new distribution upstairs
2. ... which helps justify putting in a ventilation system at the same time
3. ... which makes it logical* to do it all at the same time as a full bathroom (only one in the house) gut renovation

* More on this later

Scope creep

1. Need to run new distribution upstairs
2. ... which helps justify putting in a ventilation system at the same time
3. ... which makes it logical* to do it all at the same time as a full bathroom (only one in the house) gut renovation
4. And then there's the question of what to do about hot water for domestic use

My design ground rules

1. Keep it simple so that it is:
 - Affordable
 - Repeatable
 - Bucks the conception of hydronic systems



Image: John Siegenthaler

My design ground rules


1. Keep it simple so that it is:
 - Affordable
 - Repeatable
 - Bucks the conception of hydronic systems
2. Consult the pros

Design evolution




Starting point (circa 2016-17)

- Mono-bloc system filled with antifreeze solution
- Auxiliary boiler for subzero temps and backup
- Provision for future cooling
- 5 circulator pumps and 2 reset controllers
- No DHW or DHW preheat
- 2-pipe design




Final design (2-3 iterations later)

- Split system (no antifreeze needed)
- No added outdoor reset control
- No zone valves
- 3 circulator pumps
- Backup without auxiliary boiler
- 3-pipe design
- DHW fully independent



Zooming in...



Sizing the distribution system




Sizing the distribution system

Critical: energy modeling

Zone / Room	Design heat load	Output of existing baseboard, 180F*
2 / Bed 1	5600 btu/hr	3700 btu/hr (-1900)
2 / Bed 2	3800 btu/hr	3700 btu/hr (-100)
2 / Bed 3	1800 btu/hr	2200 btu/hr (+400)
2 / Bath	1800 btu/hr	1300 btu/hr (-500)

* Assumes 1 gpm and John Siegenthaler water temp vs. output chart, series loop begins in Bed 1 and continues in order shown in table




Sizing the distribution system

Critical: energy modeling

Zone / Room	Design heat load	Output of existing baseboard, 180F*	Output of existing baseboard, 120F*
2 / Bed 1	5600 btu/hr	3700 btu/hr (-1900)	1000 btu/hr (-4600)
2 / Bed 2	3800 btu/hr	3700 btu/hr (-100)	1000 btu/hr (-2800)
2 / Bed 3	1800 btu/hr	2200 btu/hr (+400)	700 btu/hr (-1100)
2 / Bath	1800 btu/hr	1300 btu/hr (-500)	900 btu/hr (-900)

* Assumes 1 gpm and John Siegenthaler water temp vs. output chart, series loop begins in Bed 1 and continues in order shown in table



Sizing the distribution system

Radiator right-sizing

Zone / Room	Design heat load	180F (Match manufacturer literature)
2 / Bed 1	5600 btu/hr	<u>12" x 71" (1-plate)</u>
2 / Bed 2	3800 btu/hr	<u>12" x 59" (1-plate)</u>
2 / Bed 3	1800 btu/hr	<u>12" x 24" (1-plate)</u>
2 / Bath	1800 btu/hr	<u>12" x 24" (1-plate)</u>

* Assumes 1 gpm, each room is a homerun to the mechanical room supply manifold

Sizing the distribution system

Radiator right-sizing

Zone / Room	Design heat load	180F (Match manufacturer literature)	120F
2 / Bed 1	5600 btu/hr	<u>12" x 71" (1-plate)</u>	20" x 91" (3-plate) 12" x 24" (2-plate)
2 / Bed 2	3800 btu/hr	<u>12" x 59" (1-plate)</u>	24" x 64" (3-plate)
2 / Bed 3	1800 btu/hr	<u>12" x 24" (1-plate)</u>	24" x 36" (2-plate)
2 / Bath	1800 btu/hr	<u>12" x 24" (1-plate)</u>	24" x 36" (2-plate)

* Assumes 1 gpm, each room is a homerun to the mechanical room supply manifold

If you did this, the system would be 3-4x undersized!



Sizing the distribution system

Radiator right-sizing

Zone / Room	Design heat load	180F (Match manufacturer literature)	120F																																																
2 / Bed 1	5600 btu/hr	Model 22 4" Deep <table border="1"> <thead> <tr> <th>DIMENSIONS (H X W)</th> <th>PART NUMBER</th> <th>BTU @ 180° F*</th> </tr> </thead> <tbody> <tr><td>12" x 16"</td><td>7750100604</td><td>1573</td></tr> <tr><td>12" x 24"</td><td>7750100606</td><td>2359</td></tr> <tr><td>12" x 36"</td><td>7750100609</td><td>2539</td></tr> <tr><td>12" x 48"</td><td>7750100612</td><td>4719</td></tr> <tr><td>12" x 59"</td><td>7750100615</td><td>6291</td></tr> <tr><td>12" x 71"</td><td>7750100618</td><td>7078</td></tr> <tr><td>20" x 16"</td><td>7750102604</td><td>2341</td></tr> <tr><td>20" x 24"</td><td>7750102606</td><td>3511</td></tr> <tr><td>20" x 36"</td><td>7750102609</td><td>5266</td></tr> <tr><td>20" x 48"</td><td>7750102612</td><td>7022</td></tr> <tr><td>20" x 59"</td><td>7750102615</td><td>8777</td></tr> <tr><td>20" x 71"</td><td>7750102618</td><td>10,533</td></tr> <tr><td>24" x 16"</td><td>7750103604</td><td>2713</td></tr> <tr><td>24" x 24"</td><td>7750103606</td><td>4069</td></tr> <tr><td>24" x 36"</td><td>7750103609</td><td>6104</td></tr> </tbody> </table>	DIMENSIONS (H X W)	PART NUMBER	BTU @ 180° F*	12" x 16"	7750100604	1573	12" x 24"	7750100606	2359	12" x 36"	7750100609	2539	12" x 48"	7750100612	4719	12" x 59"	7750100615	6291	12" x 71"	7750100618	7078	20" x 16"	7750102604	2341	20" x 24"	7750102606	3511	20" x 36"	7750102609	5266	20" x 48"	7750102612	7022	20" x 59"	7750102615	8777	20" x 71"	7750102618	10,533	24" x 16"	7750103604	2713	24" x 24"	7750103606	4069	24" x 36"	7750103609	6104	20" x 91" (3-plate) 12" x 24" (2-plate)
DIMENSIONS (H X W)	PART NUMBER		BTU @ 180° F*																																																
12" x 16"	7750100604		1573																																																
12" x 24"	7750100606		2359																																																
12" x 36"	7750100609		2539																																																
12" x 48"	7750100612	4719																																																	
12" x 59"	7750100615	6291																																																	
12" x 71"	7750100618	7078																																																	
20" x 16"	7750102604	2341																																																	
20" x 24"	7750102606	3511																																																	
20" x 36"	7750102609	5266																																																	
20" x 48"	7750102612	7022																																																	
20" x 59"	7750102615	8777																																																	
20" x 71"	7750102618	10,533																																																	
24" x 16"	7750103604	2713																																																	
24" x 24"	7750103606	4069																																																	
24" x 36"	7750103609	6104																																																	
2 / Bed 2	3800 btu/hr	24" x 64" (3-plate)																																																	
2 / Bed 3	1800 btu/hr	24" x 36" (2-plate)																																																	
2 / Bath	1800 btu/hr	24" x 36" (2-plate)																																																	

* Assumes 1 gpm, each room is a homerun to the

Listed output = 6104
 Adj. output = 1856
 (30% of listed)



Installation




**If there's one thing you take
away today:**

**In 99% of existing
homes, putting in a
AWHP is NOT simply a
boiler swap**


Routing

Need to get homeruns (1/2" PERT tubing pairs) from the mechanical room to EACH of 5 panel radiator locations



Routing



- Destroy 3 walls
- Close in 2 storage nooks
- Multiple holes through pine floor



Routing

- Destroy 3 walls
- Close in 2 storage nooks
- Multiple holes through pine floor

- Destroy complete finished floor
- Destroy attic floor
- Open up 1 ceiling
- Open up 2 more walls
- Dig into 3 more pine floors



Photos – Phase I (2018)



Office – 1st floor



Before...



The hope was to stop here...
Connection to mech. room


Office – 1st floor

White tube = ventilation system
Orange = PERT tubing for heating



Surprise! Whole wall needs to be padded out (due to structural beam above)

...and lost triangular storage area due to joist locations / real estate for tubing



Office – 1st floor



Note the fresh air ventilation register (top left)

Master bedroom – 2nd floor



Old baseboard



Exploratory work

Master bedroom – 2nd floor



Hope was to stop here...
(1st floor office wall is below)



...but a structural beam is in the way...

Master bedroom – 2nd floor



Entire wall needed to be padded out
(loft space is above)



Access holes to drilled
through to office
below

Master bedroom – 2nd floor



Insulation (sound, not thermal) and nailplates

Everything's in! (with PERT clips and tube strapping to keep as tidy as realistic)

Master bedroom – 2nd floor



Floor joist direction meant getting to the window wall wasn't too bad...



Although blocking halfway across necessitated creativity and small hands

Master bedroom – 2nd floor



Loft



Glued-down pine flooring was a nightmare to remove

Loft



Holes to feed 2 bedrooms and bath (south bedroom at mid-right)

Loft




Discover reason for damaged always-frosty skylight: No insulation in this cavity!



Add blocking to minimize future cellulose spillage

Loft



Kneewall to support panel radiator



New subfloor and locally-milled maple floor


Attic



Before...



Attic



All lines in!
Air sealed partitions and
holes



90s installed for
dropdowns to east
bedroom and
bathroom PERT

Ceiling ventilation
return for bathroom
below



Attic



Repack cellulose, add rockwool
Blocking plus 1.5" polyiso and
plywood



R-23 of mineral wool + 1.5" polyiso
(R-10) above all lines
New deck raised floor 1.5"

South bedroom – 2nd floor



Before...




A tricky route

South bedroom – 2nd floor



Use ceiling and closet wall / floor to access exterior wall
Cut path for PERT tubing

South bedroom – 2nd floor



Bathroom – 2nd floor



Before...

Bathroom – 2nd floor



Common wall with adjacent bedroom


Creating a PERT pathway
to exterior wall



Bathroom – 2nd floor



Putting it all together



Bathroom – 2nd floor



Reconstruction



East bedroom – 2nd floor



Baseboard out and access for
PERT in



East bedroom – 2nd floor



Mechanical room – 1st floor



Exploratory holes



Opening wall to office space


Mechanical room – 1st floor



End state 2018




A month later...



2018 summary

- 650' of PERT
- 400' of ComfoTube (for ventilation)
- Destruction tally:
 - 6 walls
 - 1 ceiling
 - 1 floor (complete), plus 4 that needed repair



2018 summary, cont.

- Lines pressure tested and mapped for future
- No upstairs heat for winter of 2018-19
- Nail plates



Photos – Phase II (2019)



Mechanical room



State, previous 10 months



Mechanical room




Status, previous 10 months



Propane out




Heat pump water heater in



Electrical
upgrades
needed

Cleaning up the mess



Plug holes



Boiler venting




Old exhaust-only ventilation



Ventilation system



Outdoor
air intake



Kitchen exhaust



Mechanical room
exhaust

Ventilation system



Ventilator hung and initial tubing connections



Operational



Fresh air intake


AWHP, buffer tank, and distribution



Floor zone manifold



Before...



After

Upstairs manifold



Outdoors



Results



Final product



Great swap!



AWHP



Master / Loft



South bedroom




East bedroom / Bathroom



House operation

Thermostats



Thermostatic radiator valves (TRVs)

Valve position	Reference temperature	Recommended setting for	
*	6°C	Frost protection	43 °F
0-1	12°C	Cellar, stairs	
1	15°C	Unoccupied room, laundry, recess	59 °F
2	17°C	Entrance hall, corridor	62.6 °F
2-3	18°C	Bedroom	64.4 °F
3	19-20°C	Kitchen	66-68 °F
3-4	20-21°C	Lounge, child's bedroom	68-70 °F
4	22°C	Bathroom	71.6 °F
5	max.	Valve completely open	

Ref: <https://www.energuide.be/en/questions-answers/to-which-temperature-do-the-digits-or-scales-on-a-thermostatic-radiator-valve-correspond/1524/>

Thermostat controls (initial)

- Zone 1 (slab)
 - 68F daytime
 - 67F nighttime
- Zone 2 (upstairs)
 - TStat set to 80F (so circulator pump runs 24/7)
 - TRVs set very low in unused rooms; Grundfos ECM pump adapts to demand; daytime typ. 10-15W
 - Master bedroom has programmable TRV (AA battery) that heats the room to 68F from 6:30pm-6:30am
 - Low-mass system doesn't take too long to warm

HPWH setting



Data: non-AWHP



Air sealing = 100 cfm improvement



Energy models, before and after

	2015	2020
HERS	76	55
Airtightness	763 cfm50	628 cfm50
Design heat load	33.1 kbtu/hr	31.1 kbtu/hr
Heat \$/yr	\$1549	\$1363 (-\$186/yr)
Total \$/yr	\$3511	\$2506 (-\$1005/yr)

Per REM/Rate v15.7.1

This project:

- AWHP replaces propane boiler
- Heat pump water heater replaces propane indirect tank
- High efficiency balanced ventilation replaces exhaust-only system
- Air sealing

Other improvements:

- 100% LEDs
- ENERGY STAR appliances
- Low flow DHW fixtures
- EPA 2020-compliant woodstove
- Previous air sealing

Energy models, before and after

	2015	2019
HERS	76	55
Airtightness	763 cfm50	628 cfm50
Design heat load	33.1 kbtu/hr	31.1 kbtu/hr
Heat \$/yr	\$1549	\$1363 (-\$186/yr)
Total \$/yr	\$3511	\$2506 (-\$1005/yr)

Per REM/Rate v15.7.1

This project:

- AWHP replaces propa
- Heat pump water hea
- High efficiency balanc
- Air sealing

Other improvements:

- 100% LEDs
- ENERGY STAR appliances
- Low flow DHW fixtures
- EPA 2020-compliant woodstove
- Previous air sealing


AWHP upgrade only:

- 1 HERS point

- \$260/year total energy


Mechanical room temperature

Summer, Jul 15 – Aug 15



Mechanical room temperature


Summer, 1 day (Jul 28-29)



Mechanical room temperature

Autumn/Winter, Oct 14 – Nov 14


● Temp (F) ● RH (%)



Temperatures, 1 week in January




CO₂ in bedroom, before/after




Ventilation and HPWH electricity

Autumn/Winter, 1 day (Nov 1)

Ventilation (W) by Date & Time



DHW (W) by Date & Time



Data: AWHP output and temperatures

Notes and disclaimer

Home operation:


- Wood burning when temp drops to 10F or below, about ½ cord burned this winter
- Zone 2 (upstairs) still uses AWHP during wood burning
- Backup resistance heat (9 kW) has not fired up yet

Data notes:

- Nov 1 2019 – Jan 22 2020
- Flow rate used is 15.55 gpm, based on averaged data (single speed)
- Slight misalignment in 1-minute eGauge and Nordic data means for some calculations, I've omitted first and last points in heat pump cycle (for instantaneous COP and output)
- For seasonal COP calculation uses cumulative data

Output (Jan 7, 12 hrs, AWHP only)

T_outdoors and T_living room by Date & Time




Average of btu/h out by Date & Time




Output (Jan 10, cool slab after days of wood heat)


T_outdoors and T_living room by Date & Time




Average of btu/h out by Date & Time




Zone 1 (slab) distribution



Zone 1 recovery after wood heat




Zone 2 distribution




Data: AWHP COP




COP, instant. (Nov 2019-Jan 2020)




COP, vs. Manufacturer Specs



Output, instant. (Nov 2019-Jan 2020)




Output, vs. Manufacturer Specs



Performance Tables ATW-65-HACW-P-1T R410a, 60 Hz, ZPS51K5E-PFV


	OUTDOOR			ELECTRICAL		INDOOR						
	Outdoor Air Temperature	Evaporating Temperature	Heat Absorbed (Btu/hr)	Compressor Current (A)	Input Power (W)	ELT	Condensing Temperature	Liquid Flow (gpm)	LLT	Delta T	Heating (Btu/hr)	COP _H
LOADING	-5°F	-16°F	7,600	20.7	4730	102°F	110°F	14	105°F	3°F	23,400	1.45
	5°F	-8°F	13,600	19.3	4410	101°F	109°F			4°F	28,300	1.88
	15°F	1°F	19,200	17.8	4100	100°F	109°F			5°F	32,900	2.35
	25°F	9°F	24,800	17.1	3950	100°F	109°F			5°F	37,900	2.81
	35°F	17°F	31,700	15.5	3620	99°F	109°F			6°F	43,700	3.55
	45°F	26°F	38,100	15.5	3610	98°F	108°F			7°F	50,100	4.07
	55°F	34°F	45,100	15.4	3570	97°F	108°F			8°F	56,900	4.68
	65°F	43°F	52,300	15.2	3490	96°F	108°F			9°F	63,900	5.37

COP: NYSERDA study (4 SpacePak AWHPs)




4 plots overlaid (by me),
from graphics within
NYSERDA / Frontier
Energy reports

COP: System comp. to NYSERDA study



COP: System comp. to NYSERDA study + VT site



Performance

Fully monitored period:

- **8.21 MMBTU heat produced (2405 kWh)**
- **967 kWh in (includes 108 kWh defrost)**
 - Includes all auxiliaries except the two distribution system circulator pumps

➔ **“Seasonal” COP 2.49***

**Assuming period is typical of the heating season
2.40 when adding in distribution system electricity*

Operational cost

Based on current usage, projected 12-month
cost of running AWHP

= \$823

Comparison

= \$1084 (replaced propane boiler)

= \$745 (new gas boiler)

Costs



Heating system costs

Category	Item	Cost
Distribution	PERT tubing	473
	Fittings and misc.	324
	Panel radiators	2182
	Panel radiator fittings, valves	243
	Manifolds – Uponor 6-loop (2)	700
	Circulator pump - Grundfos alpha2 26-99	446
	Circulator pumps - Grundfos alpha2 15-55F (2)	389
	EVT rebate – circulator pumps	-100
	Finishing work incl. non-HVAC contracted labor	2000
		Subtotal
AWHP	AWHP - Nordic ATW-65 with accessories	7590
	EVT rebate – AWHP	-5000
	Buffer tank – ecoUltra 70g with 9 kW backup	1956
	Controls and thermostat	227
	Electrical – breaker upgrade, panel rewiring	1440
	Labor, fittings, mounting hardware, refrig.	3365
	Finishing work incl. non-HVAC contracted labor	315
		Subtotal
	Total	\$16,550

Heating system costs

Category	Item	Cost	Cost, future-proof
Distribution	PERT tubing	473	
	Fittings and misc.	324	
	Panel radiators	2182	
	Panel radiator fittings, valves	243	
	Manifolds – Uponor 6-loop (2)	700	
	Circulator pump - Grundfos alpha2 26-99	446	
	Circulator pumps - Grundfos alpha2 15-55F (2)	389	
	EVT rebate – circulator pumps	-100	
	Finishing work incl. non-HVAC contracted labor	2000	
		Subtotal	\$6,657
AWHP	AWHP - Nordic ATW-65 with accessories	7590	7590
	EVT rebate – AWHP	-5000	-5000
	Buffer tank – ecoUltra 70g with 9 kW backup	1956	***
	Controls and thermostat	227	
	Electrical – breaker upgrade, panel rewiring	1440	500
	Labor, fittings, mounting hardware, refig.	3365	1500
	Finishing work incl. non-HVAC contracted labor	315	
		Subtotal	\$9,893
	Total	\$16,550	\$4,590

Rest of “system” costs

Category	Item	Cost
Ventilation	Distribution tubing and registers	1769
	Finishing work incl. non-HVAC contracted labor (Phase I)	2000
	Ventilator plus accessory parts, fittings, and filters	4709
	Electrical	150
	Finishing work incl. non-HVAC contracted labor (Phase I)	900
	Subtotal	\$9,528
DHW	Heat pump water heater (HPWH)	1719
	EVT rebate – HPWH	-500
	Parts and labor	2246
	Electrical	300
	Finishing work incl. non-HVAC contracted labor	100
	Subtotal	\$3,865

Rest of “system” costs

Category	Item	Cost
Ventilation	Distribution tubing and registers	1769
	Finishing work incl. non-HVAC contracted labor (Phase I)	2000
	Ventilator plus accessory parts, fittings, and filters	4709
	Electrical	150
	Finishing work incl. non-HVAC contracted labor (Phase I)	900
	Subtotal	\$9,528
DHW	Heat pump water heater (HPWH)	1719
	EVT rebate – HPWH	-500
	Parts and labor	2246
	Electrical	300
	Finishing work incl. non-HVAC contracted labor	100
	Subtotal	\$3,865
Heating	Subtotal	\$16,550
Total		\$29,943

Notes:

- Includes \$5600 in EVT rebates
- Retail or contractor pricing / no “free” or extra-discounted equipment

Radiator right-sizing, cost impacts

Zone / Room	Design heat load	180F (Match manufacturer literature)	120F design
2 / Bed 1	5600 btu/hr	<u>12" x 71" (1-plate)</u> \$530	\$619 + \$172 = \$791
2 / Bed 2	3800 btu/hr	<u>12" x 59" (1-plate)</u> \$500	\$511
2 / Bed 3	1800 btu/hr	<u>12" x 24" (1-plate)</u> \$260	\$247
2 / Bath	1800 btu/hr	<u>12" x 24" (1-plate)</u> \$260	\$247
Radiator cost (excl. freight, fittings, and valves)		\$1550	\$1796 (+\$246 premium)

* Assumes 1 gpm, each room is a homerun to the mechanical room supply manifold
 Prices for "Match manufacturer literature" column are hyperlinked to product, via SupplyHouse.com; note that for true apples-to-apples comparison I could have had Purmo radiators priced
 Prices for "Design for 120F supply water" are actuals paid, Purmo radiators ordered from VP Supply

Rest of “system” costs

Category	Item	Cost	Cost, future-proof
Ventilation	Distribution tubing and registers	1769	
	Finishing work incl. non-HVAC contracted labor (Phase I)	2000	
	Ventilator plus accessory parts, fittings, and filters	4709	
	Electrical	150	
	Finishing work incl. non-HVAC contracted labor (Phase I)	900	
	Subtotal		\$9,528
DHW	Heat pump water heater (HPWH)	1719	1719
	EVT rebate – HPWH	-500	-500
	Parts and labor	2246	2246
	Electrical	300	300
	Finishing work incl. non-HVAC contracted labor	100	100
	Subtotal	\$3,865	\$3,865
Heating	Subtotal	\$16,550	\$4,590
Total		\$29,943	\$8,455

Could have been worse!

- What’s my labor worth? \$10-15k?
- HVAC contractor willing to learn on his own time (and brainstormed ways to save cost)

Payback

Simple payback

- Because existing design was *incompatible*:
 - Approx. 60 years (with \$5100 EVT incentives)

Payback

Simple payback

- Because existing design was incompatible:
 - Approx. 60 years (with \$5100 EVT incentives)
- If existing design was AWHP compatible and boiler did not need replacement:
 - Approx. 20 years

Payback

Simple payback

- Because existing design was incompatible:
 - Approx. 60 years (with \$5100 EVT incentives)
- If existing design was AWHP compatible and boiler did not need replacement:
 - Approx. 20 years
- If existing design was AWHP compatible and boiler needed replacement:
 - Somewhere in the 0-5 year range

Closing thoughts



Benefits



Challenging payback as the lens

How do you attach a price to the following?

- No combustion / propane is gone

Challenging payback as the lens

How do you attach a price to the following?

- No combustion / propane is gone
- Room by room temperature control*
- Filtered fresh air ventilation
- Balanced slab heat
- Less window condensation
- Warm radiators / no possible burn surfaces
- House tightened and insulation gaps filled
- HPWH scavenges waste heat (slab, AWHP, buffer tank, pumps, electronics)
- Cool-dry zone (HPWH + no boiler)

Challenging payback as the lens

How do you attach a price to the following?

- No combustion
- Room by room
- Filtered fresh
- Balanced slak
- Less window
- Warm radiato
- House tighte
- HPWH scaveng
- tank, pumps,
- Cool-dry zone (HPWH + no boiler)




Challenging payback as the lens

How do you attach a price to the following?

- No combustion / propane is gone
- Room by room temperature control*
- Filtered fresh air ventilation
- Balance
- Less wi
- Warm
- House
- HPWH (water tank, pumps, electronics)
- Cool-dry zone (HPWH + no boiler)

If you're in this room:
"We" have to use creativity
to encourage people to see
past the \$-only approach

House as a “system”



- Heating backup:
- Electric element
 - Woodstove

Lessons learned

- Leg kit and sound insulation add-ons should be standard
- One size smaller might have been the better choice
- Haven't found controller to prioritize Zone 2 necessary (could have saved \$100)
- 2-wire to thermostats was a pain
- Emitters a bit oversized → doing just fine down to zero degrees with 105F supply
- Started heating season with outdoor reset, but AWHP runtimes so short that moved to 105F all the time
- Split vs. mono-bloc has challenges

Closing thoughts

1. AWHP not right or easy for every existing home


Closing thoughts

1. AWHP not right or easy for every existing home
2. **100% of new homes** need to be built with **low temperature infrastructure** in place
 - Beyond the tubing embedded in the concrete slab, very little was reused
 - Like balanced (fresh air) ventilation—another important feature that requires advanced planning—this is a no-brainer

Suggested “decision tree”




Decision tree: Existing homes




* Properly sized (for 120F supply) panel radiators/high-output baseboards/other emitters designed for low temperature

Decision tree: Existing homes



* Properly sized (for 120F supply) panel radiators/high-output baseboards/other emitters designed for low temperature


Decision tree: New homes



* Heat load calculation done, with buffer tank plus combination of radiant floors/surfaces and *homeruns* to any panel radiators/high-output baseboards/other emitters designed for low temperature. Alternative to homeruns is supply and return loop with zone valves at take-offs.

Don't install 2-wire to thermostat locations


Decision tree: New homes



* Heat load calculation done, with buffer tank plus combination of radiant floors/surfaces and *homeruns* to any panel radiators/high-output baseboards/other emitters designed for low temperature. Alternative to homeruns is supply and return loop with zone valves at take-offs.

Don't install 2-wire to thermostat locations

Decision tree: New homes



* Heat load calculation done, with boiler output temperature. Alternative to homeruns to any panel radiators/high temperature.

Don't install 2-wire to thermostat locations

On the horizon...



Stiebel Eltron split system


- Split (hydraulic)
- 2 sizes (specs @ A-7/W35*)
 - 43.9 kbtu/h, 2.98 COP
 - 23.4 kbtu/h, 2.83 COP
- Inverter-driven
- DHW+buffer integrated
 - Buffer 26.4gal
 - DHW 44.4gal
- Built-in backup (5.9 kW)
- Field testing 10 units in September 2020

*Outside -7C (19.4F), supply water 35C (95F)

WPL 15 ACS / WPL 25 ACS HEAT PUMPS

Comprehensive air-to-water solution


Stiebel Eltron WPL 15 & 25 ACS heat pumps use outdoor air to produce hot water for central heating, cooling, and DHW. Connection to the hot water tank inside the building is hydraulic, not refrigerant, making installation easy, affordable, and suitable for both new construction or existing system modernization.



The HSBC 200 tank comprises a DHW tank and buffer tank in a single appliance. This almost halves the space required with separate tanks side-by-side. The HSBC 200 tank can be positioned in a much smaller space – for more available floor area.

Availability Q2 2020

- › System with central heating, DHW heating and cooling functions
- › Energy efficient inverter technology for high flow temperatures
- › Low operating noise
- › Integral cooling function



Technical Data

Model	WPL 15 ACS	WPL 25 ACS	Model	HSBC 200 S
Output at A3/W35 (EN 14511)	4.23 kW	8.33 kW	Nominal Capacity, DHW tank	168 l / 44.4 gal
Coefficient of performance A2/W35 (EN 14511)	3.68	4.16	Nominal Capacity, buffer tank	100 l / 26.4 gal
Output at A-7/W35 (EN 14511)	6.86 kW	12.86 kW	Standby energy loss (24 hrs @ 65°C)	1.3 kWh
Coefficient of performance A-7/W35 (EN 14511)	2.1407 BTU/h	63.040 BTU/h	Indirect coil surface area	3.3 m ² / 35.5 ft ²
Cooling capacity at A3/W7	7.86 kW	16.88 kW	Voltage	230 V
Sound pressure level at 5 m	2.23 tons	4.23 tons	Booster heater power consumption	5.9 kW
Max. application limit on the heating side	28 (fpa)	32 (fpa)	Height	1988 mm / 75.12"
Height	600 mm / 35.43"	1045 mm / 41.14"	Width	680 mm / 26.77"
Width	1270 mm / 50.00"	1490 mm / 58.66"	Depth	875 mm / 34.29"
Depth	593 mm / 23.35"	593 mm / 23.35"	Weight	203 kg / 447.54 lb
Weight	180 kg / 392.74 lb	375 kg / 835.80 lb		

Enertech split system

- Details unknown
- Announced at AHR conference this week
- Based on NIBE (Sweden)



Enertech's Leading Edge Air-to-Water Heat Pump

A turnkey solution for the future of air-to-water heat pump technology

Enertech is bringing modern heating and cooling capabilities to projects aiming to achieve high-efficiencies, utility cost-savings, and/or net zero status with its air-to-water heat pump technology. This system achieves exceptional efficiency ratings compared to conventional air-source heat pumps, even below 0°F outside air temperatures.



Taco split system

- Split (hydraulic)
- Based on Dimplex (German)
- Size (specs @ A-7/W35*)
 - 30.5 kbtu/h, 2.8 COP
- Inverter-driven
- Buffer integrated
- One installed VT
- Available Q3 2020



*Outside -7C (19.4F), supply water 35C (95F)

SpacePak split system

- Split (refrigerant)
- Up to 68 kbtu/h
- Inverter-driven
- Operates to -22F
- Expected Q3 2020



*Outside -7C (19.4F), supply water 35C (95F)

Natural refrigerants?

1. Sanden Eco Runo

- ~~R-744 (CO₂)~~
- ~~Field trials in Pacific Northwest~~

2. Vaillant

- R-290 (propane)
- German system for sale in Europe Nov 2020



Wrap-up



I've heard:

“The technology isn't there...”

I disagree.

- Good products are out there; and more are coming
- \$1000/ton incentive in Vermont right now
- It's taking off as we speak
- Modulation isn't necessary with proper design

Takeaways

Pro:

- **Thermal comfort** and **ability to control** is fantastic – likely **far better than minisplits**
- Proper **ventilation** is great
- Separating **DHW** from the AWHP was a good move
- **Mechanical room** very full, but **useful** in a different if unconventional way than before
- No gas/propane hookups or combustion = **safety**

Takeaways

Pro:

- **Thermal comfort** and **ability to control** is fantastic – likely **far better than minisplits**
- Proper **ventilation** is great
- Separating **DHW** from the AWHP was a good move
- **Mechanical room** very full, but **useful** in a different if unconventional way than before
- No gas/propane hookups or combustion = **safety**

Con:

- **Expensive, took longer** than hoped, and was **destructive**
- There is a **0% chance** we would have done this **if not for** the simultaneous ventilation system and bathroom remodel

Takeaways

Pro:

- **Thermal comfort** and **ability to control** is fantastic – likely **far better than minisplits**
- Proper **ventilation** is great
- Separating **DHW** from the AWHP was a good move
- **Mechanical room** very full, but **useful** in a different if unconventional way than before
- No gas/propane hookups or combustion = **safety**

Combined with an induction cooktop and heat pump water heater, it's a fantastic **all-electric** package that people should be able to replicate

Would we do it again?




If any single person in this room designs or installs distribution that relies on 180F supply, in a new home, this presentation has been a failure

bjust@veic.org




Figure 3-4. Comparison of temperature cycling range for a thermal storage tank using high-temperature heat emitters versus low-temperature heat emitters




NYSERDA: Design Assistance Manual for High-Efficiency, Low-Emissions Biomass Boiler Systems
 In Residential and Commercial Buildings

Figure 7-21. Possible configurations for distribution systems based on connecting heat sources as shown in figure 7-20




NYSERDA: Design Assistance Manual for High-Efficiency, Low-Emissions Biomass Boiler Systems
In Residential and Commercial Buildings

“2-pipe” versus “4-pipe buffer tank piping



Thermal storage tank
2-pipe configuration



Thermal storage tank
4-pipe configuration