

NOTE: THIS IS NOT A RECOMMENDED DETAIL IF BUILDING A DOUBLE STUD WALL. BUT THE EXTERIOR FOUNDATION WALL INSULATION HERE ALIGNS WELL WITH THE ABOVE GRADE EXTERIOR INSULATION.

FOUNDATION WALL INSULATION, EXTERIOR, R-30 MIN.

R-40 MIN. WALL WITH CONTINUOUS EXTERIOR INSULATION. SEE ABOVE GRADE WALLS SHEET FOR OPTIONAL CONFIGURATIONS.

CAULK OR GASKET AT SILL

NOTCHED FOUNDATION -OR- CONCEAL JOINT WITH FINISH FLOORING

R-30 INSULATION UNDER SLAB

VAPOR BARRIER BELOW SLAB, WRAP UP AND SEAL TO WALL MIN. R-10


FOOTING INSULATION R-8 MIN.

### EXTERIOR INSULATION AT SLAB ON GRADE

**NOTES:**

1. DRAWING FOR INFORMATIONAL USE ONLY. NOT INTENDED TO SHOW ALL ASPECTS OF DETAIL.
2. YELLOW HIGHLIGHTS INSULATION SPECIFIC TO COMPONENT
3. DASHED RED LINE INDICATES LOCATION OF AIR/ VAPOR BARRIER. NOT A SPECIFIC MATERIAL.

**SCALE:**



Efficiency Vermont Certified: HIGH PERFORMANCE LEVEL